



LPG CONSTRUCTION PERMIT APPLICATION

Utah County Fire Marshal

51 South University Avenue, Suite 120

Provo, Utah 84601

Phone: 801-851-8348 Facsimile: 801-851-8340

www.utahcounty.gov/firemarshal

Date:

Permit Fee:

TANK TYPE FEE + ZONE FEE (+ ADDITIONAL TANK FEE IF APPLICABLE)

ABOVE GROUND TANKS:

- ☐ \$65.00 Plan review & Site Inspection
☐ \$20.00 Per additional tank at same location

BELOW GROUND TANKS:

- ☐ \$95.00 Plan review & Site Inspection
☐ \$35.00 Per additional tank at same location

<input type="checkbox"/> Zone 1	<input type="checkbox"/> Zone 2	<input type="checkbox"/> Zone 3	<input type="checkbox"/> Zone 4
10 or less miles one way	Over 10 miles one way	Over 20 miles one way	Over 30 miles one way
\$15.00	\$30.00	\$45.00	\$65.00

RECEIPT #: OFFICE USE ONLY RECEIVED BY: OFFICE USE ONLY PERMIT #: OFFICE USE ONLY

APPLICANT NAME:

PHONE NUMBER:

EMAIL:

MAILING ADDRESS:

CITY:

STATE:

ZIP:

INSTALLATION ADDRESS:

CITY/AREA:

ZIP:

PARCEL # _____

NUMBER OF TANKS:

TANK SIZE: (GALLONS):

- ☐ EXISTING TANK
☐ NEW INSTALL

STATE LICENSED LPG CONTRACTOR:

CONTRACTOR LICENSE NUMBER: OFFICE USE ONLY

LPG CONTRACTOR IS REQUIRED TO GIVE 48 HOURS INSTALLATION NOTICE FOR INSPECTION.

COPIES OF APPROVED PERMITS WILL BE SENT TO LPG CONTRACTOR BY FIRE MARSHAL'S OFFICE

☐ PLOT PLAN ATTACHED – Plot plan showing tank installation location, structures, property lines, roadways, waterways, fences, gates, and other relevant information required.

BLDG. PERMIT #: IF APPLICABLE _____

Plot plan showing tank installation location, structures, property lines, roadways, waterways, fences, gates, and other relevant information is required.

When guard posts are required, they shall be installed meeting the following requirements: (R710-8.6.5)

1. Constructed of steel not less than four inches in diameter and filled with concrete.
2. Set with spacing not more than four (4) feet apart.
3. Buried three (3) feet in the ground in concrete not less than 15 inches in diameter.
4. Set with tops of the posts not less than three (3) feet above the ground.

Minimum separation between containers and buildings, public ways or lot lines of adjoining property that can be built upon.

Container capacity (water gallons)	Mounded or underground container(s) (feet)	Aboveground container(s) (feet)	Minimum separation between containers
Less than 125 gallons	10'	5'	None
125 to 250	10'	10'	None
251 to 500	10'	10'	3'
501 to 2,000	10'	25'	3'