

**Office Handout LPG Information**

\_\_\_\_ Regular LPG (Gold envelope)

\_\_\_\_ WUI LPG (Black envelope)



# LPG CONSTRUCTION PERMIT APPLICATION

**UTAH COUNTY FIRE MARSHAL**

51 South University Avenue Suite 120, Provo Utah 84606

Phone: 801-851-8348 Facsimile: 801-851-8340

www.utahcounty.gov/firemarshal

**DATE:** \_\_\_\_\_**PERMIT FEE TOTAL: \$** \_\_\_\_\_**ABOVE GROUND TANKS**☐

\$65.00 Plan review &amp; Site Inspection

☐

\$20.00 Per additional tank at same Location

**BELOW GROUND TANKS**☐

\$95.00 Plan review &amp; Site Inspection

☐

\$35.00 Per additional tank at same Location

☐**Zone 1**☐**Zone 2**☐**Zone 3**☐**Zone 4**

10 Miles or less one way

\$15.00

Over 10 miles one way

\$30.00

Over 20 miles one way

\$45.00

Over 30 miles one way

\$65.00

Applicant must complete all blue areas.

**APPLICANT NAME:** \_\_\_\_\_**PHONE NUMBER:** \_\_\_\_\_**EMAIL:** \_\_\_\_\_**MAILING ADDRESS:** \_\_\_\_\_**CITY:** \_\_\_\_\_**STATE:** \_\_\_\_\_**ZIP CODE:** \_\_\_\_\_**INSTALLATION ADDRESS, CITY, ZIP:** \_\_\_\_\_☐**EXISTING  
TANK****TANK SIZE:** \_\_\_\_\_**STATE LICENSED LPG CONTRACTOR:** \_\_\_\_\_☐**NEW  
INSTALL****TANK SIZE:** \_\_\_\_\_**CLASS:** \_\_\_\_\_

Contractor License Number: \_\_\_\_\_ OFFICE USE

**Utah County Building Permit #** \_\_\_\_\_ **Parcel #** \_\_\_\_\_

☐ **PLOT PLAN - ATTACHE** a plot plan showing tank installation location, structures, property lines, roadways, waterways, fences, gates, and other relevant information. See page 2.

**INSPECTION REQUIRED**Please contact the Fire Inspector 48 hours in advance for inspections.

Inspections need to be completed prior to closing trenches or burying tanks.

**801-851-8355**

Permit Section RECEIPT# \_\_\_\_\_

RECEIVED BY OFFICE USE ONLY **LPG PERMIT#** OFFICE USE ONLY \_\_\_\_\_

\*All plans must be submitted and approved by the Utah County Fire Marshal prior to installation. Installations must be performed by a licensed LPG County approved contractor, licensed through the Utah State Fire Marshal's Office.

\*An official LPG permit shall always be kept on the job site and shall be readily available for review by the fire code official.

\*The LPG contractor must give a 48-hour notice to the fire code inspector prior to installation & completion of the site for an inspection.

Utah County Official Signature \_\_\_\_\_

**Void without official stamp, seal, or signature of the UC Fire Marshal**

Plot plan showing tank installation location, structures, property lines, roadways, waterways, fences, gates, and other relevant information required.

When guard posts are required, they shall be installed meeting the following requirements: (R710-8.6.5)

1. Constructed of steel not less than four inches in diameter and filled with concrete.
2. Set with spacing not more than four (4) feet apart.
3. Buried three (3) feet in the ground in concrete not less than 15 inches in diameter.
4. Set with tops of the posts not less than three (3) feet above the ground.

Minimum separation between containers and buildings, public ways or lot lines of adjoining property that can be built upon.			
Container capacity (water gallons)	Mounded or underground container(s) (feet)	Aboveground container(s) (feet)	Minimum separation between containers
Less than 125 gallons	10'	5'	None
125 to 250	10'	10'	None
251 to 500	10'	10'	3'
501 to 2,000	10'	25'	3'