

Emergency Preparedness Home Fuel Storage

Residential inside-storage of fuel should be limited to the following:

- Class I Flammable Liquids – includes gasoline: 5 gallons (not recommended)
- Class II Combustible Liquids – includes diesel fuel and kerosene: 25 Gallons (not recommended)
- Class III A Combustible Liquid – includes deodorized kerosene: 25 Gallons (deodorized kerosene is preferred over regular kerosene because it is cleaner/safer and has a higher flashpoint)
- LP-Gas – includes propane: two, one-pound cylinders

Note: This is only a brief commentary; there are exceptions. For more information or answers to specific questions, contact the Utah County Fire Marshal's Office (801) 851-8348.

References: IFC 105.6.16, IFC table 2703.1.1(1), IFC 3404.3.4.1 (7), NFPA 58 - 8.3.5